

DEMKO CERTIFICATE

Certificate No. D-05595
Page 1/3
Date of Issue 2016-12-09

Certificate Holder PM PLASTIC MATERIALS S R L
Via Xxv Aprile 15
Almenno S Bartolomeo, 24030 Bg ITALY

Manufacturer PM PLASTIC MATERIALS S R L
Via Xxv Aprile 15
Almenno S Bartolomeo, 24030 Bg ITALY

Production site PM PLASTIC MATERIALS S R L
Via Xxv Aprile 15
Almenno S Bartolomeo, 24030 Bg ITALY

Certified Product Model Conduit for electrical installations
IRL HF, IRS HF

Trademark PM

Rated Voltage / Frequency -

Rated Current / Power -

Insulation Class -

Degree of protection (IP) -

Tested acc. to EN 61386-1:2008, EN 61386-21:2004/A11:2010, EN 61386-21:2004

Test Report No. 1618847 issued on 2016-11-16

Additional This certificate replaces previous certificate NO.D-00967

Expire date 2021-07-19

Certification Manager
Jan-Erik Storgaard

This is to certify that representative sample(s) of the Product described herein ("Certified Product") have been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the D Mark Requirements. The Designated Certificate holder is entitled to use the d or for cables <DEMKO> for the Certified Product manufactured at the production site(s) identified above, in accordance with the D Mark Service Agreement, including without limitation the D Mark Testing and Certification Services Service Terms. Only those Products bearing the D Mark should be considered as being covered by UL's D Mark Service. This Certificate shall remain valid through the expiration date, unless terminated earlier in accordance with the Service Agreement including without limitation if the Standard identified on this Certificate is amended or withdrawn prior to the expiration date.

Certification Body

UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65,
info.dk@ul.com
www.ul-europe.com



Appendix DEMKO CERTIFICATE

Certificate No. D-05595
Page 2/3
Date of Issue 2016-12-09

External Certification Information:
Certificate NO. 1618847 issued 2016-11-16 by Intertek Semko AB.

Additional Information:
IRS HF
Rigid conduits of white insulated material.
Non-flame propagating conduits.
Conduit sizes: 16, 20, 25, 32, 40, 50 mm
Classification code: 234312-0-010

IRL HF
Rigid conduits of grey insulated material.
Non-flame propagating conduits.
Conduit sizes: 16, 20, 25, 32, 40, 50 mm
Classification code: 334312-0-010

Conduits comply with EN 61034-2:2005 test, for low smoke, and no halogen tests according EN 60754-1:2014 and EN 60754-1:2014 (LSZH).

Certification Body

UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com
www.ul-europe.com



Appendix DEMKO CERTIFICATE

Certificate No. D-05595
Page 3/3
Date of Issue 2016-12-09



Certification Body

UL International Demko A/S, Borupvang 5A, DK-2750
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com
www.ul-europe.com

