

# DEMKO CERTIFICATE

**Certificate No.** D-06580-M1  
**Page** 1/4  
**Date of Issue** 2018-05-24

**Certificate Holder** PM PLASTIC MATERIALS S R L  
Via Xxv Aprile 15  
Almenno S Bartolomeo, 24030 Bg Italy

**Manufacturer** PM PLASTIC MATERIALS S R L  
Via Xxv Aprile 15  
Almenno S Bartolomeo, 24030 Bg Italy

**Production site** PM PLASTIC MATERIALS S R L  
Via Xxv Aprile 15  
Almenno S Bartolomeo, 24030 Bg Italy

**Certified Product Model** Conduit for electrical installations  
ICTA\* 16, ICTA\* 20, ICTA\* 25, ICTA\* 32, ICTA\* 40, ICTA\* 50  
See Page 2

**Trademark** PM, PROFI FLEX

**Rated Voltage / Frequency** -

**Rated Current / Power** -

**Insulation Class** -

**Degree of protection (IP)** -

**Tested acc. to** EN 61386-1:2008, EN 61386-22:2004/A11:2010

**Test Report No.** 1800133 issued on 2018-04-11

**Additional** This Certificate replaces earlier issued Demko Certificate No. D-06580 to correct typographical errors in Additional Information.

**Expire date** 2023-04-11

---

**Certification Manager**  
Jan-Erik Storgaard

This is to certify that representative sample(s) of the Product described herein ("Certified Product") have been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the D Mark Requirements. The Designated Certificate holder is entitled to use the d or for cables <DEMKO> for the Certified Product manufactured at the production site(s) identified above, in accordance with the D Mark Service Agreement, including without limitation the D Mark Testing and Certification Services Service Terms. Only those Products bearing the D Mark should be considered as being covered by UL's D Mark Service. This Certificate shall remain valid through the expiration date, unless terminated earlier in accordance with the Service Agreement including without limitation if the Standard identified on this Certificate is amended or withdrawn prior to the expiration date.

**Certification Body** UL International Demko A/S, Borupvang 5A, DK-2750  
Ballerup, Denmark, Tel. +45 44 85 65 65,  
info.dk@ul.com  
www.ul-europe.com



# Appendix DEMKO CERTIFICATE

**Certificate No.** D-06580-M1  
**Page** 2/4  
**Date of Issue** 2018-05-24

## Model Details:

ICTA\* 16,ICTA\* 20,ICTA\* 25,ICTA\* 32,ICTA\* 40,ICTA\* 50

## Colour codes (\*)

None Grey  
A Blue  
N Black  
V Green  
X Ivory

## External Certification Information:

1800133, issued on 2018-04-11 by Intertek Semko AB

## Additional Information:

### EU Directive information:

According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

### ICTA\* 16

Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue color. Size 16mm. Temperature range -5/+90°C. Non-flame propagating. Classification 3422.

### ICTA\* 20

Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue color. Size 20mm. Temperature range -5/+90°C. Non-flame propagating. Classification 3422.

### ICTA\* 25

Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue color. Size 25mm. Temperature range -5/+90°C. Non-flame propagating. Classification 3422.

### ICTA\* 32

Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue color. Size 32mm. Temperature range -5/+90°C. Non-flame propagating. Classification 3422.

### ICTA\* 40

Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue color. Size 40mm. Temperature range -5/+90°C. Non-flame propagating. Classification 3422.

### ICTA\* 50

Pliable self-recovering conduit of insulated material in grey and blue color. Size 50mm. Temperature range -5/+90°C. Non-flame propagating. Classification 3422.

**Certification Body**

UL International Demko A/S, Borupvang 5A, DK-2750  
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com  
www.ul-europe.com



# Appendix DEMKO CERTIFICATE

**Certificate No.** D-06580-M1  
**Page** 3/4  
**Date of Issue** 2018-05-24

## ICTA\* 16

Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue color. Size 16mm. Temperature range -25/+90°C. Non-flame propagating. Classification 3342.

## ICTA\* 20

Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue color. Size 20mm. Temperature range -25/+90°C. Non-flame propagating. Classification 3342.

## ICTA\* 25

Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue color. Size 25mm. Temperature range -25/+90°C. Non-flame propagating. Classification 3342.

## ICTA\* 32

Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue color. Size 32mm. Temperature range -25/+90°C. Non-flame propagating. Classification 3342.

## ICTA\* 40

Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue color. Size 40mm. Temperature range -25/+90°C. Non-flame propagating. Classification 3342.

## ICTA\* 50

Pliable self-recovering conduit of insulated material in grey and blue color. Size 50mm. Temperature range -25/+90°C. Non-flame propagating. Classification 3342.

No halogen according to EN 60754-1:2014 and EN 60754-2:2014.

The conduits comply with requirement according Low Smoke "LSZH" test to IEC 61034-2:2005+A1

---


**Certification Body**

**UL International Demko A/S, Borupvang 5A, DK-2750  
Ballerup, Denmark, Tel. +45 44 85 65 65,  
info.dk@ul.com  
www.ul-europe.com**



# Appendix DEMKO CERTIFICATE

Certificate No. D-06580-M1  
Page 4/4  
Date of Issue 2018-05-24



---

**Certification Body**

UL International Demko A/S, Borupvang 5A, DK-2750  
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com  
www.ul-europe.com

