




CERTIFICATE FI 30443

Our Ref. 293116

Product	Installation conduit, pliable, set
Type	ICTA 16, ICTA 20, ICTA 25, ICTA 32, ICTA 40, ICTA 50
Trade mark	PM, PROFI FLEX
Certificate Holder	P.M. Plastic Materials S.R.L. Via XXV Aprile, 15 24030 Almenno, SAN BARTOLOMEO (BG), ITALY
Manufacturer	P.M. Plastic Materials S.R.L. Via XXV Aprile, 15 24030 Almenno, SAN BARTOLOMEO (BG), ITALY
Technical information	Size: 16 mm, 20 mm, 25 mm, 32 mm, 40 mm or 50 mm. Classification 3422 or 3342. Temperature range -5/+90 °C or -25/+90 °C.
Other information	Pliable self-recovering conduit of insulated material in ivory, green, black, grey and blue colour. Non-flame propagating.
The product is certified according to the following standard(s)	EN 61386-1:2008 EN 61386-22:2004 + A11:2010
Validity	This certificate is valid until 17 May 2023 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.
Directive information	The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.
Date of issue	17 May 2018
Signature	SGS Fimko Ltd  Matti Huttunen Certification Engineer

This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 30443

Manufacturing site

P.M. Plastic Materials S.R.L.
Via XXV Aprile, 15 24030 Almenno
SAN BARTOLOMEO (BG), ITALY

Additional information

The product has certificate 1800133 issued by Intertek Semko in accordance with Nordic Certification Service system.



No halogen according to EN 60754-1:2014 and EN 60754-2:2014.
The conduits comply with requirement according Low Smoke "LSZH" test to IEC 61034-2:2005 + A1.

Our ref:

293116-1

MOL